



ASHRAE Chapter Dayton, OH

Advanced Energy Design Guides

Merle McBride, Ph.D., P.E.

November 12, 2012

Welcome

ASHRAE Members
And
Guests



Silence is Golden



Agenda


Introduction

Background


AEDGs




ASHRAE Advanced Energy Design Guides




Office
Bldgs.




Retail
Stores




Schools
K-12







Ware
houses



Highway
Lodging



Health
Care



Advanced Energy Design Guide
for Large Hospitals

Why develop AEDGs?



What are the Primary Driving Forces?




Primary Driving Forces


- 1 - Global Energy Use
- 2 - Increasing Energy Prices
- 3 - Environmental Issues
- 4 - AIA 2030 Challenge - NZE




U.S. Energy Use




U.S. Energy Use




2000 Energy Consumption vs Population (60 Countries, 79% Pop, 68% Energy)




2000 Energy Consumption vs Population (61 Countries, 84% Pop, 93% Energy)




World Energy Consumption



National Average Commercial Natural Gas Prices




National Average Commercial Electricity Prices



Environmental


Coal-Fired Power Plant



500 megawatt:

- 1.4×10^6 tons coal
- 3.7×10^6 tons CO₂
- 1.0×10^4 tons SO₂
- 5.0×10^2 tons particulates
- 1.0×10^4 tons NO_x
- 7.1×10^2 tons CO
- 2.2×10^2 tons VOC
- 170 lbs mercury
- 225 lbs arsenic
- 114 lbs lead
- 4 lbs cadmium

U.S. Energy Use



AIA 2030 Challenge

Edward Mazria, AIA



“Net Zero Energy Buildings by 2030”

Alignment on 2030 Challenge

AIA

ASHRAE

USGBC


U.S. Conference of Mayors

State of Florida




ASHRAE Board of Directors

(April 1, 2007)



Energy Code

AEDGs



3 year development cycle
Consensus – Public Reviews
Technically Feasible
Economically Justified
Balanced
Code Language

1 year to complete
Peer Reviews
Two Manufacturers
30% to 50% Savings
Balanced
Recommendations


AEDG Background

USGBC - Leadership in Energy and Environmental Design (LEED)

- Certified, Silver, Gold, Platinum

ASHRAE Standard 90.1

- 30% Energy Savings - 1999
- 50% Energy Savings - 2004
- 75% Energy Savings



AEDG Background

Partner Organizations

Members

ASHRAE

55,000

AIA

83,000


IES

9,000

USGBC

25,000


U.S. Dept. of Energy (NREL, PNNL)



AEDG Goals


- Present *some ways, but not all or the only way* to build energy efficient buildings that use significantly less energy than those built to the minimum code requirements
- Progress toward a net zero energy building
- 30% energy savings when compared to ANSI/ASHRAE/IESNA Std. 90.1-1999
- 50% energy savings when compared to ANSI/ASHRAE/IESNA Std. 90.1-2004

Std. 90.1 & AEDG Energy Savings



SCOPE

Dodge Building Construction Activity for 1999 thru 2005
(Top six building types account for 85% of the floor area)




Scope


- Offices: 5,000 - 500,000 ft²
- Retail: 7,500 - 100,000 ft²
- Schools: 210,000 ft²
 - Elementary, Middle, High Schools
- Warehouses: 50,000 ft²
 - Bulk Storage with Office Space
 - Self Storage
- Highway Lodging: 45,000 ft²
 - Exterior Entrances
 - Interior Corridor
- Health Care: 41,000 - 425,000 ft²
 - Surgical Hospitals – 25 to 160 beds

Office Buildings


Small Office – 5,000 ft²




Small Office – 20,000 ft²



Medium – 53,600 ft²





Large – 498,600 ft²






Retail Buildings




Strip Mall – 7,500 ft²
Medium Box Retail – 40,500 ft² and Stand-alone Retail – 15,000 ft²
Big Box Retail – 99,225 ft²




Schools K-12

Elementary




High



73,930 ft²

Middle




210,810 ft²

116,080 ft²


Warehouses and Self-Storage

Self Storage



8,000 ft²


Non-refrigerated warehouse



50,000 ft²


Highway Lodging

Exterior Walk Way




14,000 ft²

Small Hotel




43,000 ft²

Hospitals and Health Care




Surgery Center – 41,000 ft²



Medium Hospital – 65,000 ft²

Large Hospital – 425,000 ft² – 160 patient beds



Development Process

- 1 - Collaboration of Partner Organizations
- 2 - Steering Committee – Scoping Document
- 3 - Project Committee – 6 to 14 Members
- 4 - Focus Group – 6 to 8 Members
- 5 - Peer Reviews – 35%, 65%, 90% Drafts
- 6 - Respond to Peer Review Remarks
- 7 - Publication



Design Strategy

Improve Energy Efficiency

Better Envelope

Lower LPD

Higher HVAC Efficiencies



Design Strategy

Change Architectural Design

Building Features

- 1 - Building Shape
- 2 - Building Size
- 3 - Number of Stories
- 4 - Building Orientation
- 5 - Building Occupancy Type



Design Strategy

Energy Conservation Measures

Envelope

Lighting – Daylighting

Equipment – Energy Star

SWH



Design Strategy

HVAC

- Packaged Single - Zone Air Source HP
- WSHP with DOAS
- VAV DX w/Indirect Gas - Fired or Elec. Internal
Heat and Elec. Perimeter Heat
- VAV CHW
- Fan Coils w/ DOAS
- Radiant Systems w/DOAS
- GSHP w/DOAS
- VAV Air – Handling System w/DOAS



Design Strategy

HVAC

- Packaged Variable Volume DX Air Conditioners
- Packaged Constant Volume DX Air Conditioners w/DOAS
- Packaged Single Zone Air Source HP w/DOAS
- Packaged Single Zone WSHP w/DOAS
- Central Air-Handling System
- Mixed Air VAV System w/Separate OA Treatment and Heat Recovery
- Radiant System w/DOAS and Displacement Ventilation and Exterior Automated Shades

What's in an AEDG?

Foreword – Schools, Health Care and all 50% AEDGs

- 1 - Introduction – Essentials of Achieving the Savings
- 2 - Integrated Design Process/Strategies
- 3 - Energy Modeling and Benchmarking Strategies
- 4 - Recommendations by Climate (the specifics)
- 5 - How to Implement Recommendations (hints, cautions)

Appendices

- A – Envelope Thermal Performance Factors
- B – International Climate Zones
- C – Commissioning

Using an Integrated Design Approach to Achieve Energy Savings

- A narrative discussion of the design and construction process that points out the opportunities for energy savings in each phase of design
- Includes reference tables that leads the user through the process of identifying, selecting energy savings measures, and defining the responsible party to meet major energy design goals

Development of Recommendations

- Recommendations for Envelope, Lighting, HVAC, and Service Hot Water that achieve at least 30% or 50% whole building energy savings
 - Additional Savings Strategies are included, but not needed to achieve target energy savings
 - Use practical off-the-shelf technologies and strategies available from multiple manufactures
- Energy is the independent variable & cost-effectiveness (e.g. payback) is the dependent variable
- Recommendations modeled to verify savings

Critical Issues

Offices – Night Ventilation, Plug Loads

Retail – Merchandise Display


Schools – Daylighting, Ventilation, Kitchens

Warehouses – Loading Docks and Trucks


Highway Lodging – Laundry

Health Care – Ventilation


15 Representative Locations





EnergyPlus Electrical Analog



Recommendation Tables by 8 Climate Zones











Climate Zone Recommendations

- Envelope
- Lighting
- HVAC
- SWH



Envelope

Roofs
Walls
Floors
Slabs
Doors
Fenestration




Envelope



Climate Zone 5 Recommendations for K-12 Schools


| Item | Component | Recommendation | How-To-Tip |
|-----------------------|---|--------------------------|--------------------|
| Roof | Insulation above deck | R-25 c.i. | EN1-2 |
| | Attic and other | R-38 | EN3, EN15-16, EN18 |
| | Metal building | R-13 + R-19 | EN3-4, EN15, EN18 |
| | SRI | Comply with Std. 90.1 | EN1 |
| Walls | Mass (HC > 7 Btu/ft ² -°F) | R-11.4 c.i. | EN5, EN15, EN18 |
| | Steel framed | R-13 + R-7.5 c.i. | EN6, EN15, EN18 |
| | Wood framed and other | R-13 + R-3.8 c.i. | EN7, EN15, EN18 |
| | Metal building | R-19 + R-5.6 c.i. | EN7, EN15, EN18 |
| | Below-grade walls | R-7.5 c.i. | EN8, EN15, EN18 |
| Floor | Mass | R-10.4 | EN9, EN15, EN18 |
| | Steel framed | R-30 | EN10, EN15, EN18 |
| | Wood framed and other | R-30 | EN10, EN15, EN18 |
| Slabs | Unheated | Comply with Std. 90.1 | EN11, EN17-18 |
| | Heated | R-15 for 24 in. | EN12, EN17-18 |
| Doors | Swinging | U-0.70 | EN13, EN18 |
| | Nonswinging | U-0.50 | EN14, EN18 |
| Vertical Fenestration | Total fenestration to gross wall area ratio | 35% Max | EN20 |
| | Thermal transmittance | U-0.42 | EN19, EN24, EN28 |
| | SHGC - all types and orientations | SHGC-0.40 | EN19, EN24, EN28 |
| | Exterior sun control (S, E, W only) | Projection Factor > 0.50 | EN21, EN23, EN26 |

Parapet



Parapet






PARAPET SECTION

SCALE: 1/2" = 1'-0"


1
7.06



PARAPET SECTION

SCALE: 1 1/2" = 1'-0"

2
7.03a



EAVE SECTION


SCALE: 1 1/2" = 1'-0"

6
7.03

Walls

Wood Framing


| | <u>90.1-1999</u> | | <u>AEDG</u> |
|----------------|------------------|----|---------------|
| Zone | 13/14 | 17 | 4 & 5 |
| R-value | 13 | 13 | 13 + 3.8 c.i. |




Walls



Steel Framing

| | <u>90.1-1999</u> | | <u>AEDG</u> |
|----------------|------------------|----|---------------|
| Zone | 13/14 | 17 | 4 & 5 |
| R-value | 13 | 13 | 13 + 7.5 c.i. |







Below Grade Walls






Below Grade Walls



Slab-on-Grade Heated

| | <u>90.1-1999</u> | | <u>AEDG</u> |
|---------|------------------|--------|-------------|
| Zone | 13/14 | 17 | 4 & 5 |
| R-value | 7.5/24" | 10/36" | 15/24" |







WALL SECTION

SCALE: 3/4" = 1'-0"



C
7.04

Windows




Projection Factor

$$\text{Minimum Projection Factor} = \frac{\text{Projection}}{\text{Height Above Sill}}$$



SHGC Multipliers for Projection Factors



Air Infiltration

Continuous Air Barrier System

- 1 - Exterior envelope
- 2 - Interior separations between conditioned and unconditioned spaces


Lighting

- Interior Finishes
- Interior Lighting
 - Daylighted Option
 - Nodaylighted Option




Toplighting


- Daylighting for top floor or single story
- North or South facing clerestories



Sidelighting



Sidelighting with Toplighting



Lighting

Climate Zone 5 Recommendations for K-12 Schools

| Item | Component | Recommendation | How-To-Tip |
|---|--|--|-----------------|
| Interior Finishes | Interior room surface average reflectance | 70%+ on ceilings and walls above 7 ft 50%+ on walls below 7 ft | DL14, EL1 |
| Interior Lighting - Daylighted Option | Classroom daylighting (daylighting fenestration to floor area ratio) | Toplighted - South-facing roof monitors: 8%-11% North-facing roof monitors: 12%-15% | DL1-19, DL28-35 |
| | | Sidelighted - South-facing: 8%-11% North-facing: 15%-20% | DL1-19, DL20-27 |
| | | Combined toplighted and sidelighted - South-facing sidelighted: 6%-8% Toplighted: 2%-3% North-facing sidelighted: 9%-13% Toplighted: 3%-5% | DL1-19, DL20-35 |
| | Gym toplighting (daylighting fenestration to floor area ratio) | South-facing roof monitors: 5%-8% North-facing roof monitors: 7%-10% | DL1-19, DL36-37 |
| | LPD | 1.2 W/ft ² maximum | EL9-16 |
| | Light source system efficacy (linear fluorescent) | 75 mean lm/W minimum | EL2-3, EL5 |
| | Light source system efficacy (all other sources) | 50 mean lm/W minimum | EL4-5 |
| | Occupancy controls | Manual on, auto off all zones | EL6, EL8, DL16 |
| | Dimming controls daylight harvesting | Dim all fixtures in classrooms and gym and other fixtures within 15 ft of sidelighting edge and within 10 ft of toplighting edge | DL16 |
| Interior Lighting - Nondaylighted Option | LPD | 1.1 W/ft ² | EL9-16 |
| | Light source system efficacy (linear fluorescent) | 85 mean lm/W minimum | EL2-3, EL5 |
| | Light source system efficacy (all other sources) | 50 mean lm/W minimum | EL4-5 |
| | Occupancy controls - general | Manual on, auto off all zones | EL6, EL8, DL16 |
| | Dimming controls daylight harvesting | Dim fixtures within 15 ft of sidelighting edge and within 10 ft of toplighting edge | DL16 |

HVAC

Climate Zone 5 Recommendations for K-12 Schools

| Item | Component | Recommendation | How-To Tip |
|--|--|--|------------------------|
| Packaged DX Rooftops (or DX Split Systems) | Air conditioner (<65 kBtu/h) | 13.0 SEER | HV1, HV7-8, HV10 |
| | Air conditioner (≥65 and <135 kBtu/h) | 11.0 EER | |
| | Air conditioner (≥135 and <240 kBtu/h) | 10.8 EER | |
| | Air conditioner (≥240 kBtu/h) | 10.0 EER and 10.4 IPLV | |
| | Heat pump (<65 kBtu/h) | 13.0 SEER/7.7 HPSF | |
| Packaged DX Rooftops (or DX Split Systems) | Heat pump (≥65 and <135 kBtu/h) | 10.6 EER/3.2 COP | HV1, HV7-8, HV10 |
| | Heat pump (≥135 kBtu/h) | 10.1 EER and 11.0 IPLV/3.1 COP | |
| | Gas furnace (<225 kBtu/h) | 80% AFUE or E_f | |
| | Gas furnace (≥225 kBtu/h) | 80% E_c | HV13 |
| | Economizer | >54 kBtu/h | |
| | Ventilation | Energy recovery or demand control | |
| | Fans | Constant volume: 1 hp/1000 cfm Variable volume: 1.3 hp/1000 cfm | |
| WSHP System | Water-source heat pump (<65 kBtu/h) | Cooling: 12.0 EER at 86F Heating: 4.5 COP at 68F | HV2, HV7-8, HV10 |
| | Water-source heat pump (≥65 kBtu/h) | Cooling: 12.0 EER at 86F Heating: 4.2 COP at 68F | |
| | GSHP (<65 kBtu/h) | Cooling: 14.1 EER at 77°F and 17.0 EER at 59°F Heating: 3.5 COP at 32°F and 4.0 COP at 50°F | HV2, HV7-8, HV10, AS4 |
| | GSHP (≥65 kBtu/h) | Cooling: 13.0 EER at 77°F and 16.0 EER at 59°F Heating: 3.1 COP at 32°F and 3.5 COP at 50°F | |
| | Gas boiler | 85% E_c | HV2, HV7, HV10 |
| | Economizer | Comply with Standard 90.1* | |
| | Ventilation | DOAS with either energy recovery or demand control | HV9, HV11-12, HV14 |
| | WSHP duct pressure drop | Total ESP < 0.2 in. H ₂ O | |
| Unit Ventilator and Chiller System | Air-cooled chiller efficiency | 9.6 EER and 11.5 IPLV | HV3, HV7-8, HV10, HV25 |
| | Water-cooled chiller efficiency | Comply with Standard 90.1* | |
| | Gas boiler | 85% E_c | HV3, HV7, HV10, HV26 |
| | Economizer | >54 kBtu/h | |
| | Ventilation | Energy recovery or demand control | HV9, HV11-12, HV14 |
| | Pressure drop | Total ESP < 0.2 in. H ₂ O | |

HVAC

Climate Zone 5 Recommendations for K-12 Schools

| Item | Component | Recommendation | How-To Tip |
|-----------------------------|--|--|------------------------|
| Fan Coil and Chiller System | Air-cooled chiller efficiency | 9.6 EER and 11.5 IPLV | HV4, HV7–8, HV10, HV25 |
| | Water-cooled chiller efficiency | Comply with Standard 90.1* | HV4, HV7–8, HV10, HV25 |
| | Gas boiler | 85% E_c | HV4, HV7, HV10, HV26 |
| | Economizer | Comply with Standard 90.1* | HV13 |
| | Ventilation | DOAS with either energy recovery or demand control | HV9, HV11–12, HV14 |
| | Pressure drop | Total ESP < 0.2 in. H_2O | HV19 |
| Packaged Rooftop VAV System | Rooftop air conditioner (≥ 240 kBtu/h) | 10.0 EER and 10.4 IPLV | HV5, HV7–8, HV10 |
| | Gas furnace (≥ 225 kBtu/h) | 80% E_c | |
| | Gas boiler | 85% E_c | HV5, HV7, HV10, HV26 |
| | Economizer | >54 kBtu/h | HV13 |
| | Ventilation | Energy recovery or demand control | HV9, HV11–12, HV14 |
| | Fans | 1.3 hp/1000 cfm | HV19 |
| VAV and Chiller System | Air-cooled chiller efficiency | 9.6 EER and 11.5 IPLV | HV6–8, HV10, HV25 |
| | Water-cooled chiller efficiency | Comply with Standard 90.1* | HV6–8, HV10, HV25 |
| | Gas boiler | 85% E_c | HV6–7, HV10, HV26 |
| | Economizer | >54 kBtu/h | HV13 |
| | Ventilation | Energy recovery or demand control | HV9, HV11–12, HV14 |
| | Fans | 1.3 hp/1000 cfm | HV19 |
| Ducts and Dampers | Outdoor air damper | Motorized | HV11, HV13 |
| | Friction rate | 0.08 in. w.c./100 ft | HV16 |
| | Sealing | Seal Class B | HV18 |
| | Location | Interior only | HV16 |
| | Insulation level | R-6 | HV17 |

HVAC System Report Card

| No. | System | Energy Efficiency | Sound | IAQ | First Cost | Maintenance | System Life | Overall |
|-----|----------------------------------|-------------------|-------|-----|------------|-------------|------------------------------|---------|
| 1 | Packaged Rooftop (CV or VAV) | C | A | C | A | A | 15 to 20 | |
| 2 | WSHP - Boiler/Tower | A | B | A | B | B | 5 to 10, (longer for boiler) | |
| 3 | Unit Ventilators and Chillers | B | C | A- | A | C | 25 | |
| 4 | Fancoils and Chillers | B | B | A | B | C | 25 | |
| 5 | GSHP | A+ | B | A | C | B+ | 5 to 10, (50 yrs for loop) | |
| 6 | Packaged Rooftop VAV with Reheat | B | A | B | B+ | A | 15 to 20 | |

SWH

Climate Zone 5 Recommendations for K-12 Schools

| Item | Component | Recommendation | How-To-Tip |
|------|--|-----------------------------|------------|
| SWH | Gas storage (>75 kBtu/h) | 90% E_t | WH1-5 |
| | Gas instantaneous | 0.81 EF or 81% E_t | WH1-5 |
| | Electric (storage or instantaneous) | EF > 0.99 - 0.0012 x volume | WH1-5 |
| | Pipe insulation ($d < 1.5$ in/ $d \geq 1.5$ in) | 1 in./1.5 in. | WH6 |

Validation




Figure 4-2 Elementary End Uses: No Daylighting

Technology Examples and Case Studies



Case Studies

Present techniques and methods that are discussed in the Guide.



How-To-Implement Recommendations

| | | 30% | | | | | | 50% | | | |
|---------------------------------|------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Topic | | Office | Retail | K-12 | WH | HL | HC | SMO | K-12 | Big Box | Hospitals |
| Envelope | EN | 42 | 32 | 28 | 27 | 25 | 31 | 40 | 33 | 27 | 29 |
| Daylighting | DL | 13 | 10 | 37 | 10 | 11 | 28 | 20 | 42 | 10 | 21 |
| Electric Lighting | EL | 17 | 28 | 16 | 21 | 21 | 32 | 25 | 25 | 33 | 24 |
| Exterior Lighting | EX | 8 | 4 | 4 | 4 | | 3 | | | | |
| Plug Loads | PL | 3 | 5 | | 5 | 5 | 5 | 6 | 6 | 8 | 17 |
| Kitchen Equipment | KE | | | | | | | | 7 | | |
| Service Water Heating | WH | 6 | 6 | 6 | 6 | 8 | 6 | 6 | 7 | 6 | 7 |
| HVAC | HV | 23 | 23 | 32 | 24 | 26 | 27 | 36 | 28 | 31 | 41 |
| Quality Assurance | QA | 16 | 16 | 13 | 16 | 17 | 11 | 14 | 18 | 17 | 21 |
| Additional Savings | AS | | | 8 | | | | 7 | 6 | 1 | 5 |
| Renewable Energy | RE | | | | | 4 | | 3 | 4 | 4 | 4 |
| Natural Ventilation | NV | | | | | | | 10 | | | |
| Electrical Distribution Systems | ED | | | | | 3 | | | | | 3 |
| Ventilation Control | VC | | | | 1 | 2 | | | | | |
| Miscellaneous Appliances | MA | | | | | 2 | | | | | |
| Ground Coupled Heat Pumps | GCHP | | | | | 1 | | | | | |
| Water Conserving Equipment | WC | | | | | 1 | | | | | |
| Combined Heat and Power | CHP | | | | | 1 | | | | | |
| Other Hot Water Systems | HW | | | | | 1 | | | | | |
| Total | | 128 | 124 | 144 | 114 | 128 | 143 | 167 | 176 | 137 | 172 |

Additional Savings

- Energy Star Appliances
- Exterior Lighting
- Ventilation Control
- Electrical Distribution Systems
- Plug and Phantom Loads
- Ground Source & Ground Coupled Heat Pumps
- Peak Demand Reduction
- Photovoltaic Systems
- Solar Hot-Water Systems
- Daylighting
- Water Conservation

Table A1. Envelope Thermal Performance Factors

| Opaque Construction Options | | | | | |
|------------------------------|----------|------------------------------|----------|------------------------------|----------|
| Roof Assemblies | | Walls, Above Grade | | Floors | |
| Insulation Above Deck | | Mass Walls | | Mass | |
| R | U | R | U | R | U |
| 25 | 0.039 | 5.7 c.i. | 0.151 | 4.2 c.i. | 0.137 |
| | | 7.6 c.i. | 0.123 | 6.3 c.i. | 0.107 |
| | | 9.5 c.i. | 0.104 | 8.3 c.i. | 0.087 |
| | | 11.4 c.i. | 0.090 | 10.4 c.i. | 0.074 |
| | | 13.3 c.i. | 0.080 | 12.5 c.i. | 0.064 |
| | | 15.2 c.i. | 0.071 | 16.7 c.i. | 0.051 |
| Metal Building | | Metal Building | | Steel Framed | |
| R | U | R | U | R | U |
| 19 | 0.065 | 16 | 0.093 | 19 | 0.052 |
| 13 + 13 | 0.055 | 19 | 0.084 | 30 | 0.036 |
| 13 + 19 | 0.049 | 19+5.6 c.i. | 0.057 | 38 | 0.032 |
| 19 + 19 | 0.046 | 19+11.2 c.i. | 0.043 | | |
| Attic and Other | | Steel Framed | | Wood Framed and Other | |
| R | U | R | U | R | U |
| 30 | 0.032 | 13 | 0.124 | 19 | 0.051 |
| 38 | 0.027 | 13+3.8 c.i. | 0.084 | 30 | 0.033 |
| 60 | 0.017 | 13+7.5 c.i. | 0.064 | | |
| | | 13+10 c.i. | 0.034 | | |
| | | Wood Framed and Other | | Slabs | |
| | | R | U | Unheated | |
| | | 13 | 0.089 | R-in | F |
| | | 13+3.8 c.i. | 0.064 | 7.5-12 | 0.54 |
| | | 13+7.5 c.i. | 0.051 | 15-24 | 0.52 |
| | | 13+10 c.i. | 0.045 | 20-24 | 0.51 |
| | | Walls, Below Grade | | Heated | |
| | | Below Grade Walls | | R-in | F |
| | | R | C | 7.5-12 | 1.02 |
| | | 7.5 c.i. | 0.119 | 7.5-24 | 0.95 |
| | | 15 c.i. | 0.063 | 10-24 | 0.90 |
| | | | | 15-24 | 0.86 |
| | | | | 15-Full | 0.44 |

Commissioning

Design
Construction
Operation

Conclusions

- 30% to 50% Site Energy Savings
- Dedicated Commitments
- Specific Building Types
- Prescriptive Recommendations
- Climate Sensitive
- One Way, Not the Only Way

AEDG


Free Downloads:

www.ashrae.org/freeaedg







Downloads November 8, 2012

| | |
|-----------------------------|----------|
| 1 - Small Offices | – 99,649 |
| 2 - Small Retail | – 66,697 |
| 3 - Schools K-12 | – 74,488 |
| 4 - Warehouses/Self Storage | – 60,422 |
| 5 - Highway Lodging | – 24,588 |
| 6 - Health Care | – 35,448 |
| 7 - Small – Medium Office | – 41,328 |
| 8 - K-12 Schools | – 15,638 |
| 9 - Large Box Retail | – 18,461 |
| 10 - Large Hospitals | - 7,338 |

| | |
|---------------------|---------|
| Free Downloads | 444,057 |
| Printed Copies Sold | 22,550 |
| Total Copies | 466,607 |



ASHRAE Advanced Energy Design Guides



Office
Bldgs.

Retail
Stores





Schools
K-12

Ware
Houses

Highway
Lodging

Health
Care

Q & A



Merle McBride, Ph.D., P.E.